

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1319:103

Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: Home Automation, Inc., 5725 Powell Street, Suite A, New Orleans, LA 70123
Contact: David Hatty (504) 736-9810 Fax (504) 736-9290

DESIGN: Models 20A00-1, -2, -3, -4, -5, and -12 combination household fire and burglary alarm systems. Units are intended to be used with Models 10A02-1 and 10A02-2 enclosures. Refer to listee's printed data sheet for additional detailed product description and operational considerations. System components:

RATING: 120 VAC Primary, 12 VDC Standby

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as household fire alarm systems for use with separately listed electrically compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation Instruction Manual for details.

NOTE:

1. Burglary and other non-fire functions were not examined.
2. For **Fire Alarm Verification** feature (delay of fire alarm signal) shall NOT be used in California.

11-24-2002 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **NOVEMBER 24, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager